



SIL

Functional Safety Verification

No. 3H161209.KVQW80

Certificate's Holder: KACE VALVE (Hangzhou) Co., Ltd.
No 16, Kang Hui Road, Gongshu District, Hangzhou,
P.R.China

Product: Ball Valve (Floating Ball)
Model(s): F1, F2, F1M, F2M

Standard: IEC 61508

Verification Mark:



The Verification Mark can be affixed on the product. It is NOT permitted to alter the Verification Mark in any way

Notes: Systematic Integrity: SIL 3 Capable
Random Integrity: Type A device
SIL 3 @ HFT=0,1001
PFD_{AVG} and architecture constraints be verified for each application

Remark: This SIL Verification of Compliance has been issued on a voluntary basis. ECM confirms that a Test Report is existent for the above listed product(s) and found to meet the requirements of above standards for application in safety related system up to Safety Level of SIL 3.

The unit must be properly designed into a Safety Instrument Function as per the requirements in the Safety Manual. The Verification Mark shown above can be affixed on the product. It is NOT permitted to alter the Verification Mark in any way. In addition the Verification's Holder is NOT allowed to transfer the Verification to third parties. This certificate can be checked for validity at www.entecerma.it

Date of issue 09 December 2016

Expiry date 08 December 2021

Chief Manager
Marco Marina

Deputy Manager
Amanda Payne

Ente Certificazione Macchine

Via Cà Bella, 243 - 40053 Valsamoggia Loc. Castello di Serravalle (Bo) Italy
☎ +39.0516705141 📠 +39.0516705156 ✉ info@entecerma.it 🌐 www.entecerma.it

شهادة - 증명서 - Certificat - 證明書 - Сертификат - Certificate